



CITY OF SAN MARCOS
STANDARD PRODUCTS LIST

SPL No. WW-701

Sheet 1 of 1

for

MANHOLE INSERTS

ISSUED: 09/01/2014

REVISED: __/__/__

DESCRIPTION:

Manhole Inserts; either stainless steel or polycarbonate.

-Stainless Steel: 316 Stainless Steel not less than 16 gauge thick, straight-sided metal, , with neoprene gasket, Nitrile relief valve, and 3/16-inch diameter 316 Stainless Steel anti-theft tether 5 feet long.

-Polycarbonate material: Comply with UL Standard 94, and meet all associated ASTM specifications related to Polycarbonate. Dish thickness shall be a uniform 1/8" thick or greater. Gasket to be 1/2" wide and shall have a minimum thickness of 1/8". The Lift Strap shall be made from a woven polypropylene material, securely adhered to the inflow dish body interior, with a corrosion resistant fastener assembly.

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
1/2/2003	SOUTHWESTERN PACKING AND SEALS P.O. Box 19369 Shreveport, LA 71149-0369	Rainstopper
9/1/2014	USSI 752 Commerce Drive Venice, Florida 34292	Inflow Defender Max

NOTE:

1. Polyethylene inserts are not allowed.