



**CITY OF SAN MARCOS  
STANDARD PRODUCTS LIST**

SPL No. WW-65A

Sheet 1 of 1

for

**POLYETHYLENE TUBING FOR RECLAIMED WATER SERVICES**

**ISSUED: 01/01/2020**

**REVISED: 01/01/2022**

**DESCRIPTION:** Tubing, polyethylene, meeting ASTM D 2737, CTS-OD, 1", made of PE 4710, minimum Pressure Class 250 psi (SDR-9), solid purple wall or purple shell over clear or blue core, with contrasting-color heat-indented printline. Only compression fittings recommended by the manufacturer used with stainless steel insert stiffeners may be used.

<b>APPROVAL DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>
01/01/20	ENDOT INDUSTRIES, INC. 60 Green Pond Road Rockaway, NJ 07866	EndoTrace PE 4710 (ASTM D2737)
01/01/22	ENDOT INDUSTRIES, INC. 60 Green Pond Road Rockaway, NJ 07866	EndoPure See Note 1
01/01/22	SILVER-LINE PLASTICS CORP. 900 Riverside Drive Asheville, NC 28804	Silver-Line Ultra-Pure See Note 1
01/01/22	ADVANCED DRAINAGE SYSTEMS (ADS) 4640 Trueman Boulevard Hilliard, OH 43026	PolyFlex 4710 See Note 1

**NOTE:**

1. Must add a 14AWG Standard Copper tracer wire with HDPE Insulation per SPL WW-597C.
- 2.
- 3.
- 4.
- 5.